

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 3240-1501:108

Page 1 of 1

CATEGORY: Duct Smoke Detector Housing/Bases

LISTEE: Edwards Signaling, 8985 Towne Center Parkway, Badenton, FL 34202
Contact: Jewell Micochero (941) 739-4358 *FAX (941) 308-81234

DESIGN: Model 2435P and 6260A-CU Duct Smoke Detector Unit. Unit consists of a metal enclosure, relay, electrical components, a separately listed open area detector, a detector base and a sampling and exhaust tubes. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Air Velocity: 300-4000 fpm

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and UL label.

APPROVAL: Listed as duct smoke detector housing units for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

FORMERLY: 3240-1388:104

XL: **3240-1591:108**

*Rev. 05-24-05



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 29, 2008

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO**, Chief
Fire Engineering Division